

SWITCH-China: A Systems Approach to Decarbonizing China's Power System

Gang He,^{*,†,‡,§} Anne-Perrine Avrin,^{‡,§} James H. Nelson,[⊥] Josiah Johnston,^{‡,§} Ana Mileva,[⊥] Jianwei Tian,[#] and Daniel M. Kammen^{*,‡,§,||}

[†]Department of Technology and Society, College of Engineering and Applied Sciences, Stony Brook University, Stony Brook, New York 11794, United States


[‡]Renewable and Appropriate Energy Laboratory, [§]Energy and Resources Group, and ^{||}Goldman School of Public Policy, University of California, Berkeley, California 94720, United States

[⊥]Energy and Environmental Economics, Inc. (E3), San Francisco, California 94104, United States

[#]China National Institute of Standardization, Beijing 100191, P.R. China

Supporting Information

ABSTRACT: We present an integrated model, SWITCH-China, of the Chinese power sector with which to analyze the economic and technological implications of a medium to long-term decarbonization scenario while accounting for very-short-term renewable variability. On the basis of the model and assumptions used, we find that the announced 2030 carbon peak can be achieved with a carbon price of \sim \$40/tCO₂. Current trends in renewable energy price reductions alone are insufficient to replace coal; however, an 80% carbon emission reduction by 2050 is achievable in the Intergovernmental Panel on Climate Change Target Scenario with an optimal electricity mix in 2050 including nuclear (14%), wind (23%), solar (27%), hydro (6%), gas (1%), coal (3%), and carbon capture and sequestration coal energy (26%). The co-benefits of carbon-price strategy would offset 22% to 42% of the increased electricity costs if the true cost of coal and the social cost of carbon are incorporated. In such a scenario, aggressive attention to research and both technological and financial innovation mechanisms are crucial to enabling the transition at a reasonable cost, along with strong carbon policies.



INTRODUCTION

Today, China's power sector accounts for 50% of the country's total greenhouse-gas emissions and 12.5% of the global energy-related carbon emissions.¹ The transition from the current fossil-fuel-dominated electricity supply system to a sustainable, resource-wise system will shape how the country (and, to a large extent, the world) address local pollution and global climate change. Although coal is the dominant energy source today, ongoing rapid technological changes coupled with strategic national investments in transmission capacity and new nuclear, solar, and wind generation demonstrate that China has the capacity and willingness to perform a thorough energy transition.^{2,3} The progression to a low-carbon development, in fact, is the official goal of the Chinese government. In the 2014 United States–China joint announcement on climate change and China's intended national determined contribution (INDC), China announced its determination to peak its carbon emissions around 2030 and reach 20% of nonfossil sources in its primary energy mix by the same year.^{4,5} Installed wind capacity has sustained a remarkable 80% annual growth rate since 2005, making China a global leader with over 95.81 gigawatts (95.81

GW; and 7% of national capacity, or C_N, capacity) of installed capacity in 2014, while the United States rank second with 65.88 GW (6% of C_N), and Germany is third with 39 GW (21% of C_N).^{6,7} China's solar-power installed capacity has also been growing at an unprecedented pace. Its grid-connected solar photovoltaic (PV) capacity has reached 28.05 gigawatts (GW) by the end of 2014 (2% of C_N), a 30-fold increase in four years from 0.90 GW in 2010.^{8–10} In addition, half of all of the new nuclear power plants planned by 2030 worldwide are to be built in China. However, the multitude of wind- and solar-power curtailment in China highlights the necessity to perform a thorough planning to optimize the installation of such systems in parallel with the transmission network and storage technologies.

The efficient use of this new generating capacity and the integration of even larger quantities of clean energy require a platform in which investment and operational decisions can be

Received: March 17, 2016

Revised: May 6, 2016

Accepted: May 8, 2016

Published: May 8, 2016

optimized to meet reliability and cost management objectives on a previously unstudied scale, particularly for rapidly growing cities. Carbon capture and sequestration (CCS), shale-gas development, and new hydropower infrastructure all add additional complexity to this system. Lacking from the discussion of these resources is an open-access platform to explore the implications of different investment options for energy generation, transmission, and storage in China, as well as a means to examine the implications of different operating decisions and network topologies. Such a tool would enhance the opportunity for shared learning and dialogue around the engagement in a cost-effective decarbonization of the electricity system. The SWITCH-China model presented in this paper fills this need.

MATERIALS AND METHODS

A range of models exist that provide important perspectives on China's long-term energy supply and demand challenges.^{11–15} Macroscale models provide insights into the resource constraints that national and regional energy systems face.^{16,17} For China, these models mainly focus on the management of coal as a main future energy source because of its current predominance in the country's electricity mix.^{16,18,19} Existing studies that use an optimization model to identify the best pathways for long-term electricity mix transition^{20–24} have low geographical and temporal resolutions that are often limited to national scale and annual demand, therefore not accounting for the crucial role of electricity transmission as well as the short-time-scale variability of renewable energy. For the exploration of the realistic management of energy generation and transmission assets, a new generation of big-data models is needed. To address this need, we have developed a high-resolution integrated model that accurately reflects the performance of each element of the electricity system.²⁵

Explorations of the opportunity for China to transition to a low-carbon power sector must be performed through an accurate representation of the performance of variable solar and wind resources so that the overall system's reliability and costs can be evaluated. Only within this framework can the impacts of physical transmission bottlenecks, supply constraints, and realistic policy choices be studied. Because the multidimensional scope of energy models are limited by computing time, SWITCH-China favors an accurate representation of the grid operation, through high spatial and temporal resolution, over a larger scope that would include not only the electricity mix but also transportation and heating.

The SWITCH model is a linear program whose objective function is to minimize the cost of producing and delivering electricity through the construction and retirement of various power generation, storage, and transmission options between present day and future target dates (over the 2050 horizon) according to projected demand. SWITCH optimizes both the long-term investment and the short-term operation of the grid. It uses a combination of existing and new grid assets. Optimization is subject to reliability, operational, and resource-availability constraints as well as both existing and possible future climate policies.^{26–29} In SWITCH-China, we parametrize the entire power system as an optimization problem, permitting studies of the most cost-effective long-term investment and operational decisions across China.

A set of models exist to demonstrate that deep decarbonization (generally taken as 80% or more reductions in total CO₂ emissions) in the power sector by 2050 is physically possible

for regions of the United States.^{30–35} The overwhelming dominance of coal in China today implies that models simply based on aggregate resources of fossil fuels, hydropower, and variable renewable resources are not sufficient to examine how a transition to a low-carbon future can be managed from operational and financial standpoints. We use the SWITCH-China model to combine high spatial and temporal fidelity with detailed information on both renewable energy resources as well as on the cost and performance of specific energy technologies. This combination is needed to explore the cost and reliability impacts of specific policy choices to help China meet its future energy and environmental targets. SWITCH-China builds on detailed resource potential assessment of wind and solar availability at provincial level^{7,36} and uses time-synchronized historical hourly load and generation profiles at the provincial scale. Cost, construction time, and technological performance projections are exogenous to the optimization ([Supporting Information page S30](#)). Future electricity demand is provided by the State Grid Energy Research Institute ([Supporting Information page S24](#)). Assumptions for future generation technologies, including CCS and storage technologies, are provided in [Supporting Information page S29](#).

We consider four major scenarios: a Business-as-Usual (“BAU”) scenario in which no carbon constraints are applied, a Business-as-Usual with Carbon Cap scenario, which differs from the BAU scenario only by the inclusion of China's official 2030 carbon constraints, a Low-Cost Renewables scenario, and an IPCC Target scenario (see [Table 1](#)).

Table 1. Model Scenario Description

Scenario Name	Carbon Constraints
Business-As-Usual (“BAU”)	2010 base, no carbon constraints
Business-As-Usual with Carbon Cap (“BAU with Carbon Cap”)	2020 carbon intensity target and 2030 peak emission commitment
Low-Cost Renewables (“Low Cost Renewables”)	2010 base, aggressive wind and solar learning curve, no carbon constraints
IPCC Target (“IPCC Target”)	2020 carbon intensity target, 2030 peak emission, and 2050 80% carbon reduction on 1990 level

The assumptions in the Business-as-Usual Scenario and Business-as-Usual with Carbon Cap Scenario (“BAU with Carbon Cap” hereafter) are consistent with the current projections for future technology costs. Future availability and costs of fossil fuel, nuclear, hydropower, and renewable energy assets are exogenous data. “BAU with Carbon Cap” reflects China's existing carbon policies: its 2020 carbon intensity target and 2030 peak-carbon commitment.

In the Low-Cost Renewables scenario (“Low-Cost Renewables” hereafter), we model high levels of cost declines in wind and solar technologies. This scenario is an aggressive scale-up of a number of technology-oriented efforts, similar to the U.S. *SunShot*²⁹ program and the U.S. national roadmap for wind power. This scenario is consistent with the country-supported growth of solar and wind manufacturing and deployment in China.³⁷ Specifically, we assume that the capital cost of wind will decrease to half of its 2010 costs by 2020, and then it will remain stable at the 2020 level until 2050. Similarly, we assume that solar costs will decrease until they reach the 2020 *SunShot* value,³⁸ and then remain stable at the 2020 level until 2050. We use a cost for storage consistent with projections from the U.S. ARPA-E program.³⁹ No carbon constraints are applied in this scenario.

In the IPCC Target scenario (“IPCC Target”), we restrict the “BAU with Carbon Cap” further by adding an overall carbon emission target of 80% below the 1990 level baseline in 2050, as proposed in the 2 °C scenario recommended by the Intergovernmental Panel on Climate Change (IPCC).⁴⁰

China currently has existing policy targets in place to reach 15% of primary energy from non-fossil sources by 2020 and newly updated to 20% by 2030 (100 GW for solar and 200 GW for wind energy as proposed in “Energy Development Strategy Action Plan 2014–2020”).^{2,4,5,41,42} In addition, China has targets in place of 40 to 45% reductions in carbon intensity below the 2005 level by 2020 and has announced an extension of efforts to achieve 60 to 65% reductions by 2030 and peak carbon emissions around 2030.⁵ Today, China is well on track to achieve its short-term energy targets, with more wind and solar capacity installed each year than what would be needed to achieve those targets (Table SI-2). However, long-term carbon mitigation and technology pathways are more uncertain.

RESULTS

Starting from the base-year 2010 electricity supply mix, the existing transmission network, SWITCH-China calculates that a carbon price of \$30/tCO₂ is needed to achieve the 45% carbon intensity target in 2020. A carbon price of \$40/tCO₂ is needed to peak CO₂ emissions in 2030. We find that a carbon price would boost the installation of wind and solar as well as the transition from planned coal facilities to nuclear and natural gas. A carbon price is not as hypothetical as one could think. China has already launched several cap-and-trade pilot programs in Beijing, Shanghai, Tianjin, Guangdong, Shenzhen, Wuhan, and Chongqing,^{43,44} with a price range of RMB20–130 (\$3–\$20). In fact, the Chinese government has stated that a national cap-and-trade program will be set up as early as 2017. A carbon price of \$30/tCO₂ by 2020 and \$40/tCO₂ by 2030 is not a substantial transition from existing carbon markets.

We find that China’s 2020 energy-intensity target and continuous commitment to peak its carbon emissions by 2030 heavily impact the final-power-sector emissions and technology choices. A 40–45% carbon intensity reduction below the 2005 level translates into maintaining the total annual carbon emission between 4.5 and 4.9 Bt CO₂, whereas the “BAU” scenario shows that carbon emissions would be 8.1 Bt CO₂ in 2020.⁴⁵ The 2030 commitment as modeled in the “BAU with Carbon Cap” scenario is a real diversion from the “BAU” scenario, where China will have to curb its power sector emissions by 1.5 BtCO₂ by 2030 compared to the “BAU” scenario and by 0.5 BtCO₂ by 2030, even with low-cost renewables (see Figure 1).

By comparing the “BAU” and “Low-Cost Renewables” scenarios, we observe that a renewable technology-oriented policy driven by a large manufacturing base and low prices, as seen in recent years, is important but not sufficient to significantly reduce the rate of deploying new coal-fired power plants and, thus, the growth in carbon emissions. The “Low-Cost Renewables” scenario shows that an aggressive learning curve for renewables would replace about 300 GW of coal compared to the “BAU” scenario by 2050. In addition, this scenario deploys 40 GW more gas capacity between today and 2050 than the “BAU” scenario thanks to this source’s flexibility in ramping up and down to integrate variable resources. Despite this, coal and coal with CCS would still dominate the energy mix by 2050, representing 70% of total electricity generation under the “BAU” scenario and still providing 62% of total electricity in the “Low-Cost Renewables” scenario in 2050.




Figure 1. Carbon emission trajectory for the Chinese power sector under the four scenarios.

The “Low-Cost Renewables” scenario demonstrates that an 80% reduction in carbon emissions by 2050 would not be achieved solely through economic competition of low-cost renewables with fossil-fueled alternatives. However, as shown in the “IPCC Target” scenario the 80% target can be achieved, even absent major technological innovation, at a somewhat higher system cost via a combination of solar, wind, storage, nuclear, and CCS. In the medium- and long-term, nuclear energy becomes competitive in this scenario because its high capacity factor provides a stable baseload with little carbon emissions, and it is installed to its maximum reasonable capacity by 2050, about 300 GW. A total of 80% of the 1000 GW coal capacity needs to be coupled with CCS systems. The remaining demand will be met with wind and solar capacities, which together will supply half of the total demand in 2050. Electricity costs change from \$64.3/MWh in the “BAU” scenario to \$87.8/MWh in the “IPCC Target” scenario in 2050, a 37% increase driven by the large-scale installation of wind, solar, CCS, and storage (Figure 2).

High penetration of wind and solar systems by 2050 challenges the operation of the grid. With such a large expansion in variable energy resources, a large-scale deployment of storage assets to smooth the output, and an increase in baseload nuclear energy, the operation of the country’s power system is no easy task. The system dispatch (Figure 3) shows seasonal pattern of renewable electricity generation. Wind has better availability in winter and spring, and solar and hydropower are more productive during summer and fall. The ramp-up and-down of solar energy during the daytime creates significant needs for short-term storage, even though solar energy matches peak demand fairly well. The role of natural gas is limited despite its flexibility because of its comparatively high price and carbon-emission rate.

As of 2013, the global installed capacity of grid energy storage is 130 GW, and China accounts for 17% of this amount, with about 22 GW.⁴⁶ Our results show that by 2050, China will need 600 GW of storage to integrate variable wind and solar resources in the “IPCC Target” scenario, which represents twice the amount of estimated additional grid-connected electricity storage capacity (310 GW) needed in the United States, Europe, China, and India, an estimate based on the results of the IEA Energy Technology Perspectives 2014 (ETP 2014) 2 °C scenario (2DS) vision for energy storage.⁴⁷ Given China’s plans to have 70 GW of pumped hydro storage online by 2020, and has approximately 200 GW of pumped storage potential, the remaining storage capacity needed will have to come from other




Figure 2. Installed power-generation capacity mix for the four scenarios.




Figure 3. Year 2050 dispatch schedule for “IPCC Target” scenario. Note: an 80% carbon reduction is achievable in China’s power system by a combination of wind, solar, storage, CCS and nuclear. This system will require a large amount of storage capacity to provide operational flexibility. Storage charges 8% of the generation power on average and 26% maximum when solar generation is peaking. Storage discharge provides on average 9% of system load, and 30% maximum during nighttime.

sources. This requires the development of storage technologies that have not been implemented on a large scale yet.

Decarbonizing China’s power sector would also require new transmission lines to connect electricity-generation regions and demand centers. The optimal electricity mix constrained by the 2020 national target and the 2050 “IPCC Target” shows that coal will largely be phased out by 2050 (Figure 4). Coal plants with CCS are built in provinces where coal prices are comparatively cheap (notably in Xinjiang, Inner Mongolia, Shaanxi, and Jilin). Nuclear capacity would significantly expand on the country’s eastern coast. Several provinces present high potentials for solar

and wind power. Large transmission capacity is built to send power from Xinjiang, Qinghai, Inner Mongolia, and Shaanxi to Beijing, Tianjin, Shanghai, Zhejiang, Guangdong, and other coastal demand centers. Transmission capacity makes coal in Xinjiang available at a competitive cost, although the province shows high-quality wind and solar. Tibet has good potential for wind and solar; however, transmission infrastructure will not be built in this province because of its remote location unless related transmission costs decrease significantly over the study period.

National policy actions consistent with the “IPCC Target” scenario would have a high positive impact on fuel-cost saving,




Figure 4. Generation, transmission, and storage capacity needed to achieve an 80% carbon reduction in 2050. All represented lines are new transmission expansion. Inner Mongolia emerges as a major center of clean energy generation thanks to the combination of its location (a few hundred kilometers from major demand centers) and high-quality renewable energy resources.

air-pollution reduction, and other co-benefits. Increased energy costs resulting from this strategy would be partially offset by the decrease in costs from lower environmental pollution as well as public health and climate benefits. To quantitatively capture the benefits in concept, we use the results from emerging literature on the “external cost of coal”, which include the life-cycle environmental cost of the coal value chain.^{48–50} The external cost of coal in China is reported to range between 204.76 RMB/t (~\$30 \$/t) and 260 RMB/t (~\$40 \$/t);^{49–51} the resulting benefits from reduced coal represent between 500 and 950 billion USD. The extra cost of the “IPCC Target” scenario is 2269 billion USD annually in 2050 compared to the “BAU” scenario. The benefits of a decarbonized power sector would therefore offset 22% to 42% of the increased power cost in 2050 (Table S8). The co-benefits of decarbonization would increase beyond this level if a higher value were to be placed on local pollution reduction relative to the figures used in this paper.

DISCUSSION

By optimizing capacity expansion and hourly generation dispatch simultaneously, SWITCH-China is uniquely suited to explore both the value of and synergies among various power-system technology options, providing policymakers and industry leaders with important information about the development of the electricity grid. SWITCH-China helps identify the least-expensive response to achieving national energy and climate

targets: we demonstrate that a carbon price of \$30/tCO₂ by 2020 is needed to meet the 2020 carbon intensity target and of ~\$40/tCO₂ by 2030 for the 2030 carbon peak commitment.

To reach an 80% reduction in CO₂ emissions by 2050 in line with the IPCC’s findings, the resulting optimal electricity mix in 2050 would include nuclear (14%), wind (23%), solar (27%), hydro (6%), gas (1%), coal (3%), and CCS coal (26%) energy. This will result in a 37% increase in total power cost over the “BAU” scenario. In such a scenario, aggressive attention to research and both technological and financial innovation mechanisms are crucial to enabling the transition at a reasonable cost along with strong carbon policies.

China’s power sector is evolving, and there are many uncertainties that can impact the pathway of decarbonization. We discussed in the Supporting Information in detail the key sensitivities to the cost of carbon, the limit of nuclear energy, and the cost of CCS (Supporting Information page SI–S38). In addition, the currently cited demand projection is driven by GDP growth and energy-efficient technologies, which both include potential uncertainties.⁵² Fuel-price fluctuation and new fuel availabilities may also change optimal technology choices and impact the competitive advantage of the various technologies over time. Current cost assumptions embed uncertainties that will appear in the learning curve of new technologies and do not include external costs and systems-integration costs. Other policy developments not directly related to economics, such as

nuclear safety and security, public perception, and acceptance of nuclear and hydro projects, may add uncertainty to the applications of available technologies. We plan to include a more robust uncertainty analysis module in the next phase of model development. Future developments of SWITCH-China will also account for demand-side impact by the electrification of transportation and heating, as well as demand response and resource depletion. Co-optimization under carbon, water, and land-use constraints would also be a key theme for future studies. Energy-extraction limitations resulting from a high concentration of wind turbines in the same spot are not currently modeled but might be integrated in a future version of SWITCH-China using a subprovincial spatial resolution.

China's power sector is in the midst of fast development, and today's investment decisions will have a large impact on the country's ability to achieve its environmental and carbon mitigation targets. SWITCH-China is the "facilitator" that helps understand how technologies, policies, and investment decisions can be coupled and enables strategic thinking on the future of China's transition to a low-carbon power system. Concerted action is needed to develop such a system, including introducing a meaningful carbon price, coordinating the investment decisions, and building the necessary infrastructure for moving energy around.

■ ASSOCIATED CONTENT

📄 Supporting Information

The Supporting Information is available free of charge on the ACS Publications website at DOI: 10.1021/acs.est.6b01345.

Additional details on the SWITCH model and data, China's carbon targets and power sector emissions, model scenario descriptions, the benefits of low-carbon power transition, and key sensitivity analysis. Tables showing important sets and indices, investment and dispatch decision variables, objective functions, transmission project costs in regional grids, technology-specific targets in China's power sector, new generator parameters, connection cost types in SWITCH-China, China's national carbon targets in power sectors, wind-cost assumptions, solar-cost assumptions, benefits of China's low-carbon power transition, and carbon price sensitivity assumptions. Figures showing load areas and regional grids in SWITCH-China, typical daily load profiles by hour and yearly load profiles by month, total projected load in 2030 for each load area, China's development of non-fossil-fuel capacity and targets, average coal prices in China in 2010, generator and storage overnight capital costs in each investment period, and the impact of carbon price, nuclear limits, and CCS costs to the capacity mix in 2050. (PDF)

■ AUTHOR INFORMATION

Corresponding Authors

*E-mail: gang.he@stonybrook.edu.

*E-mail: kammen@berkeley.edu.

Notes

The authors declare no competing financial interest.

■ ACKNOWLEDGMENTS

The authors thank two anonymous reviewers for their invaluable comments. We thank Xuxuan Xie, Hongyou Lu, Daniel Sanchez, Diego Barido, Shiyu Huang, Kate Yu, Shuyu Yang, Xiao Su, Yu

Chen, Hua Yuan, and Nan Yuan for their help with some of the data and charts used in the model. We thank Dr. Zhaoguang Hu and Prof. Shiqiu Zhang for the advice. We thank the Karsten Family Foundation Endowment for the support of Renewable and Appropriate Energy Laboratory. We also thank 3TIER for the data support.

■ REFERENCES

- (1) IEA. *World Energy Outlook 2011*; International Energy Agency: Paris, 2011.
- (2) NEA. *Solar Power Development 12th Five-year Plan*; National Energy Administration: Beijing, 2012.
- (3) State Council. *Energy Development 12th Five-year Plan*; State Council: Beijing, 2013.
- (4) White House. *U.S.–China Joint Announcement on Climate Change*. Office of the Press Secretary: Washington, D.C., 2014.
- (5) NDRC. *Enhanced actions on climate change: China's intended nationally determined contributions*; National Development and Reform Commission: Beijing, 2015.
- (6) CEC. Brief on the Operation of Power Industry in 2014. <http://www.cec.org.cn/guihuayutongji/gongxufenxi/dianliyunxingjianshu/2015-02-02/133565.html> (accessed November 15, 2015). In Chinese.
- (7) He, G.; Kammen, D. M. Where, when and how much wind is available? A provincial-scale wind resource assessment for China. *Energy Policy* **2014**, *74*, 116–122.
- (8) Zheng, C.; Kammen, D. M. An innovation-focused roadmap for a sustainable global photovoltaic industry. *Energy Policy* **2014**, *67*, 159–169.
- (9) Li, J.; Wang, S.; Chang, Y.; Gao, H.; Dong, L.; Hu, R. *China Solar PV Outlook 2011*; China Environment Press: Beijing, 2011.
- (10) National Energy Administration. Statistical Data of PV Generation in 2014. http://www.nea.gov.cn/2015-03/09/c_134049519.htm (accessed November 15, 2015).
- (11) CAE. *China Energy Medium and Long-term (2030, 2050) Development Strategy Research*; Science Press: Beijing, 2011.
- (12) Jiang, K.; Hu, X.; Liu, Q.; Zhuang, X.; Liu, H. 2050 China Low Carbon Development Scenario Research. In *2050 China Energy and CO₂ Emissions Report*; 2050CEACER, Ed.; Science Press: Beijing, 2010.
- (13) Wang, T.; Watson, J. Scenario analysis of China's emissions pathways in the 21st century for low carbon transition. *Energy Policy* **2010**, *38* (7), 3537–3546.
- (14) Zhou, N.; Fridley, D.; McNeil, M.; Zheng, N.; Ke, J.; Levine, M. *China's Energy and Carbon Emissions Outlook to 2050*; Lawrence Berkeley National Laboratory: Berkeley, CA, 2011.
- (15) Mischke, P.; Karlsson, K. B. Modelling tools to evaluate China's future energy system – A review of the Chinese perspective. *Energy* **2014**, *69*, 132–143.
- (16) Cai, W.; Wang, C.; Wang, K.; Zhang, Y.; Chen, J. Scenario analysis on CO₂ emissions reduction potential in China's electricity sector. *Energy Policy* **2007**, *35* (12), 6445–6456.
- (17) Chen, Q.; Kang, C.; Xia, Q.; Guan, D. Preliminary exploration on low-carbon technology roadmap of China's power sector. *Energy* **2011**, *36* (3), 1500–1512.
- (18) Zhou, W.; Zhu, B.; Fuss, S.; Szolgayová, J.; Obersteiner, M.; Fei, W. Uncertainty modeling of CCS investment strategy in China's power sector. *Appl. Energy* **2010**, *87* (7), 2392–2400.
- (19) Zhu, L.; Fan, Y. Optimization of China's generating portfolio and policy implications based on portfolio theory. *Energy* **2010**, *35* (3), 1391–1402.
- (20) Chandler, W.; Chen, S.; Gwin, H.; Lin, R.; Wang, Y. *China's Future Generation: Assessing the maximum potential for renewable power sources in China to 2050*; WWF-US: Washington D.C., 2014; p 70.
- (21) De Laquil, P.; Wenying, C.; Larson, E. D. Modeling China's energy future. *Energy Sustainable Dev.* **2003**, *7* (4), 40–56.
- (22) Hu, X.; Jiang, K.; Yang, H. Application of AIM/Enduse Model to China. In *Climate Policy Assessment*; Kainuma, M., Matsuoka, Y., Morita, T., Eds.; Springer: Tokyo, Japan, 2003; pp 75–91.

- (23) Jiang, K.; Liu, Q.; Zhuang, X.; Hu, X. Technology roadmap for low carbon society in China. *Journal of Renewable and Sustainable Energy* **2010**, *2* (3), 1008.
- (24) Zhang, D.; Liu, P.; Ma, L.; Li, Z.; Ni, W. A multi-period modelling and optimization approach to the planning of China's power sector with consideration of carbon dioxide mitigation. *Comput. Chem. Eng.* **2012**, *37*, 227–247.
- (25) Zheng, N.; Zhou, N.; Fridley, D. *Comparative Analysis of Modeling Studies on China's Future Energy and Emissions Outlook*; Lawrence Berkeley National Laboratory: Berkeley, CA, 2010.
- (26) Fripp, M. Switch: A Planning Tool for Power Systems with Large Shares of Intermittent Renewable Energy. *Environ. Sci. Technol.* **2012**, *46* (11), 6371–6378.
- (27) Nelson, J.; Johnston, J.; Mileva, A.; Fripp, M.; Hoffman, I.; Petros-Good, A.; Blanco, C.; Kammen, D. M. High-resolution modeling of the western North American power system demonstrates low-cost and low-carbon futures. *Energy Policy* **2012**, *43*, 436–447.
- (28) Sanchez, D. L.; Nelson, J. H.; Johnston, J.; Mileva, A.; Kammen, D. M. Biomass enables the transition to a carbon-negative power system across western North America. *Nature Clim. Change* **2015**, *5*, 230–234.
- (29) Mileva, A.; Nelson, J. H.; Johnston, J.; Kammen, D. M. SunShot Solar Power Reduces Costs and Uncertainty in Future Low-Carbon Electricity Systems. *Environ. Sci. Technol.* **2013**, *47* (16), 9053–9060.
- (30) Short, W.; Sullivan, P.; Mai, T.; Mowers, M.; Uriarte, C.; Blair, N.; Heimiller, D.; Martinez, A. *Regional energy deployment system (ReEDS)* **2011**, 94.
- (31) Williams, J. H.; DeBenedictis, A.; Ghanadan, R.; Mahone, A.; Moore, J.; Morrow, W. R.; Price, S.; Torn, M. S. The Technology Path to Deep Greenhouse Gas Emissions Cuts by 2050: The Pivotal Role of Electricity. *Science* **2012**, *335* (6064), 53–59.
- (32) Hart, E. K.; Jacobson, M. Z. A Monte Carlo approach to generator portfolio planning and carbon emissions assessments of systems with large penetrations of variable renewables. *Renewable Energy* **2011**, *36* (8), 2278–2286.
- (33) Budischak, C.; Sewell, D.; Thomson, H.; Mach, L.; Veron, D. E.; Kempton, W. Cost-minimized combinations of wind power, solar power and electrochemical storage, powering the grid up to 99.9% of the time. *J. Power Sources* **2013**, *225*, 60–74.
- (34) Jacobson, M. Z.; Delucchi, M. A.; Bazouin, G.; Bauer, Z. A. F.; Heavey, C. C.; Fisher, E.; Morris, S. B.; Piekutowski, D. J. Y.; Vencill, T. A.; Yeskoo, T. W. 100% clean and renewable wind, water, and sunlight (WWS) all-sector energy roadmaps for the 50 United States. *Energy Environ. Sci.* **2015**, *8*, 2093–2117.
- (35) Jacobson, M. Z.; Delucchi, M. A.; Cameron, M. A.; Frew, B. A. Low-cost solution to the grid reliability problem with 100% penetration of intermittent wind, water, and solar for all purposes. *Proc. Natl. Acad. Sci. U. S. A.* **2015**, *112* (49), 15060–15065.
- (36) He, G.; Kammen, D. M. Where, when and how much solar is available? A provincial-scale solar resource assessment for China. *Renewable Energy* **2016**, *85*, 74–82.
- (37) NDRC. *On promoting the health development of solar PV industry*; 24; Beijing, 2013; http://www.gov.cn/zwqk/2013-07/15/content_2447814.htm (accessed on November 15, 2015).
- (38) DOE. *SunShot Vision Study*; Department of Energy: Washington D.C., 2012.
- (39) Gur, I.; Sawyer, K.; Prasher, R. Searching for a Better Thermal Battery. *Science* **2012**, *335* (6075), 1454–1455.
- (40) IPCC. *Climate Change 2007: Impacts, Adaptation and Vulnerability*; Cambridge University Press: Cambridge, UK, 2007.
- (41) NEA. *Wind Development 12th Five Year Plan*; National Energy Administration, National Development and Reform Commission, 2012.
- (42) State Council. *Energy Development Strategy Action Plan (2014–2020)*; State Council: Beijing, 2014.
- (43) Lo, A. Y. Carbon emissions trading in China. *Nat. Clim. Change* **2012**, *2* (11), 765–766.
- (44) NDRC. *Notice on Carbon Emission Trading Pilot Program*; NDRC: Beijing, China, 2011; vol. 2601.
- (45) Liao, X.; Ji, J.; Ma, X. Consistency analysis between technology plans and reduction target on CO₂ emissions from China's power sector in 2020. *China Environmental Science* **2013**, *33* (3), 553–559.
- (46) Akhil, A. A.; Huff, G.; Currier, A. B.; Kaun, B. C.; Rastler, D. M.; Chen, S. B.; Cotter, A. L.; Bradshaw, D. T.; Gauntlett, W. D. *DOE/EPRI 2013 Electricity Storage Handbook in Collaboration with NRECA*; Sandia National Laboratories: Albuquerque, NM, 2013.
- (47) IEA. *Technology Roadmap: Energy Storage 2014*; International Energy Agency: Paris, 2014; p 7.
- (48) Epstein, P. R.; Buonocore, J. J.; Eckerle, K.; Hendryx, M.; Stout, B. M., III; Heinberg, R.; Clapp, R. W.; May, B.; Reinhart, N. L.; Ahern, M. M.; et al. Full cost accounting for the life cycle of coal. *Ann. N. Y. Acad. Sci.* **2011**, *1219* (1), 73–98.
- (49) Mao, Y.; Sheng, H.; Yang, F. *The True Cost of Coal*; Greenpeace, WWF, and The Energy Foundation: Beijing, 2008.
- (50) CAEP. *The External Environmental Cost of Coal*; China Academy of Environmental Planning: Beijing, 2014.
- (51) Teng, F. *The True Cost of Coal 2012*; Coal Cap; Natural Resources Defense Council: Beijing, 2014; p 23.
- (52) He, G.; Lin, J.; Yuan, A. *Economic Rebalancing and Electricity Demand in China*; LBNL-1003799; Lawrence Berkeley National Laboratory: Berkeley, CA, 2015.